



245 CAPITOL LANE  
WINCHESTER, VIRGINIA, USA 22602  
TEL + 1-540-542-6300  
[QUESTION@TREX.COM](mailto:QUESTION@TREX.COM)  
[WWW.TREX.COM](http://WWW.TREX.COM)

22 April 2013

Re: Trex® Transcend™ BAL Fire Rating

To Whom It May Concern:

Full scale bushfire deck testing of Trex Transcend square edge and grooved edge decking was performed in accordance with AS 1530.8.1-2007 by Exova Warrington® an accredited third party Australian lab.

The performance results are as follows:

<b>Product</b>	<b>Test Result</b>
<b>Trex Transcend Square Edge</b>	<b>BAL A29</b>
<b>Trex Transcend Grooved Edge</b>	<b>BAL A19</b>

Full copies of the test report are available on an as requested basis.

Please advise if you have any questions, or if Trex can be of any assistance.

Thank you,

Kyle W. Lancaster  
Director of Technical Services  
Trex Company, Inc.  
+1-540-542-6854